

WILLIAM R. HARBRON, Ed.D.
Superintendent of Schools
w.harbron@dover.k12.nh.us

LIBBY M. SIMMONS
Business Administrator
l.simmons@dover.k12.nh.us



CHRISTINE BOSTON, Ed.D.
Director of Pupil Personnel Services
c.boston@dover.k12.nh.us

PAULA GLYNN
Director of Curriculum, Instruction and
Assessment
p.glynn@dover.k12.nh.us

THE DOVER SCHOOL DISTRICT
SCHOOL ADMINISTRATIVE UNIT #11
McCONNELL CENTER
61 LOCUST STREET SUITE 409
DOVER, NEW HAMPSHIRE 03820-4132
TEL (603) 516-6800
FAX (603) 516-6809

May 21, 2018
Vendor Questions
Request for Bid: Overhead Devices

Q. Are all walls drywall?

A. Garrison: Most, if not all walls at Garrison Elementary School are concrete block.
From Architects: All raceways are surface. We provided a pathway for AV (your use). It is 2400 series Wiremold with 2400 series Wiremold boxes. We have a detail on drawing E70.2 which is attached, detail 2.

A. New High School: Yes.

Q. That all connection plates will be located on the wall below the projector. If they are to be located elsewhere in the room, how far will it be from the projector. This information allows us to determine cable length.

A. Garrison: They are on the wall below and to the side. Will be mounted in the middle of a 18 foot long wide whiteboard/tackboard combo, so a horizontal run in addition to the vertical drop. See attached file for a typical classroom elevation.

A. New High School: Located on the wall below the projector.

Q. What connections do you want at the wall? That is # of HDMI connections, # of VGA connections, # of USB connections, # of data connections if any. This information helps determine the type of plate we need to specify.

A. Garrison: VGA, 1 HDMI, 1 USB

A. New High School: There are two data outlets at the projector location.

Dover School District Mission Statement
Empowering All Learners!